

# Intelligent LED Driver (Constant Current)

- Housing made from SAMSUNG/COVESTRO's V0 flame retardant PC materials.

  • Ultra small, thin and lightweight, screwless end cap.
- Change the output current, Dimming mode and other parameters on the NFC programmer or via the App, and sync the parameters to the driver.
- · Set the output current down to 1mA
- Automatically recognize 0-10V and 1-10V input signal.
- Ultra-low consumption of 0-10V ports < 0.05mA.
- Class 2 LED driver, Safety Extra Low Voltage (SELV).
- Soft-on and fade-in dimming function enhances your visual comfort.
- T-PWM™ dimming technology allows quality and high-end lighting.
- The whole dimming process is flicker-free with high frequency exemption level.
- $\bullet\,$  Comply with the EU's ErP Directive, networked standby<0.5W.
- $\bullet\,$  Multiple current levels, wide voltage range, suitable for LEDs with different power
- When there is no load, the output will be 0V to prevent damage to LEDs due to poor contact.
- Overheat, over voltage, overload, short circuit protection and automatic recovery.
- Suitable for Class | / || / || indoor light fixtures.
- Normal service life can reach 100,000 hours.
- 5-year warranty (Rubycon capacitor).

4 in 1 dimming 0-10V 1-10V 10V PWM RX





Flicker Free IEEE 1789

10000:1














# **Technical Specs**

Model		SE-40-3	300-1050-W1A		SE-30-200-800-W1A	
	Output Type	Constant current				
Features	Dimming Interface		-10V, 10V PWM, RX)			
	Output Feature	Isolation				
	Protection Grade	IP20				
	Insulation Grade		(Suitable for class I/ II /I	II light fixtures		
	Output Voltage	9-42Vdc		in agric inital est		
OUTPUT	Maximum output voltage	9-42/0C ≤55Vdc				
	Output Current Range	300-105	Ωm Λ		200-800mA	
	_ · _ · _ ·	2.7W-40W 1.8W-30W				
	Output Power Range Dimming Range					
	LF Current Ripple	0~100%, down to 0.01%  <3%(Maximum current for non dimming state)				
	Current Accuracy	±5%				
	PWM Frequency	≤3600Hz				
	DC Voltage Range	120-300Vdc				
	AC Voltage Range	100-240Vac				
	Input Voltage	115Vac/230Vac				
	Frequency	50/60Hz				
	Input Current	<0.45A/115Vac, <0.22A/230Vac <0.34A/115Vac, ≤0.17A/230Vac				
	Power Factor	PF>0.95/115Vac (at full load), PF>0.9C/230Vac (at full load)				
INPUT	THD		%/230Vac, at full load		I	
	Efficiency (Typ.)	88% 87%				
	Inrush Current	Cold sta	rt 25A(Test twidth=130u	us tested under 50% Ipeak)/230Vac		
	Anti Surge	L-N: 2KV				
	Leakage Current	Max. 0.	5mA			
ENVIRONMENT	Working Temperature	ta: -20 -	- 45°C tc: 90°C			
	Working Humidity	20 ~ 95%RH, non-condensing				
	Storage Temperature/Humidity	-40 ~ 80°C/10~95%RH				
	Temperature Coefficient	±0.03%/	°C(0-50°C)			
	Vibration	10-500Hz, 2G 12min/1cycle, 72 min for X, Y and Z axes respectively				
	Overload Protection	Automatically protect the device when the load exceeds 102% of the rated power. Automatically recover once load is reduced				
DDOTECTION	Overheat Protection	Intelligently adjust or turn off the current output if the PCB temperature >110°C. When the PCB temperature <90°C, automatically recover normal output				
PROTECTION		Automatically protect the device when voltage exceeds the no-load voltage. It can be recovered automatically				
	Overvoltage Protection	Automa	tically protect the device	e when voltage exceeds the no-load voltage. It o	an be recovered automatically	
	Overvoltage Protection Short Circuit Protection			e when voltage exceeds the no-load voltage. It can also sites and recover automatically	an be recovered automatically	
		Enter hi			an be recovered automatically	
	Short Circuit Protection	Enter hi	ccup mode if short circu	uit occurs, and recover automatically	an be recovered automatically	
	Short Circuit Protection Withstand Voltage	Enter hi	ccup mode if short circu 2: 3750Vac	uit occurs, and recover automatically	an be recovered automatically	
	Short Circuit Protection Withstand Voltage	Enter hi	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C	uit occurs, and recover automatically	an be recovered automatically	
	Short Circuit Protection Withstand Voltage	Enter hi I/P-0/F I/P-0/F CCC	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China	uit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14	an be recovered automatically	
	Short Circuit Protection Withstand Voltage	Enter hi I/P-O/F I/P-O/F CCC TUV	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China Germany	uit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493	an be recovered automatically	
	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-O/F I/P-O/F CCC TUV CB	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China Germany CB Member States European Union	uit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13	an be recovered automatically	
	Short Circuit Protection Withstand Voltage	Enter hi I/P-O/F I/P-O/F CCC TUV CB CE	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China Germany CB Member States	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13, EN62384	an be recovered automatically	
	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-O/F I/P-O/F CCC TUV CB CE KC EAC	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China Germany CB Member States European Union Korea	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13	an be recovered automatically	
	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-O/F I/P-O/F CCC TUV CB CE KC EAC	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, AS 61347-2-13	an be recovered automatically	
SAFETY	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC	ccup mode if short circu 2: 3750Vac 2: 100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia	C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, KC61347-2-13  AS 61347-1, AS 61347-2-13  EN61347-1, AS 61347-2-13		
SAFETY &	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA	ccup mode if short circular street if 2:3750Vac 2: 100M0/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, AS 61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, EN61347-2-13, EN62384		
	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS	ccup mode if short circular street if 2:3750Vac 2: 100M0/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India	C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, AS 61347-2-13  EN61347-1, AS 61347-2-13, EN62384  BS EN 61347-1, EN61347-2-13, EN62384  BS EN 61347-1, EN61347-2-13, EN62384		
&	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short c	Dit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, AS 61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN 61347-1, BS EN 61347-1, BS EN 61347-2-13, BS EN G1347-1, BS EN G1347-2-13, BS EN G1347-2-1		
&	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short c	Lit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  AS 61347-1, BC61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN 15 15885 (PART 2/SEC 13)  CSA C22.2 NO.250.13  UL 8750		
&	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short c	Lit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1	1 62493	
&	Short Circuit Protection Withstand Voltage Insulation Resistance Safety Standards	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short c	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  AS 61347-1, BEC61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN	1 62493	
&	Short Circuit Protection Withstand Voltage Insulation Resistance	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short c	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, BS 61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN  IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN	1 62493	
&	Short Circuit Protection Withstand Voltage Insulation Resistance Safety Standards	Enter hi I/P-O/F I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC	ccup mode if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short c	it occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN  IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN  KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015	I 62493	
&	Short Circuit Protection Withstand Voltage Insulation Resistance Safety Standards	Enter hi I/P-O/F I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short c	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, AS 61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, EN61347-2-13, EN62384  BS EN 61347-1, EN61347-2-13, EN62384  IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN  KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3-3, EN	N61547	
&	Short Circuit Protection Withstand Voltage Insulation Resistance Safety Standards	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL CCC CE KC EAC CUL CCC CE KC CUL CCC CE KC COL CCC CCE KC CCC CCC CCC CCC CCC CCC CCC	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short circular street in short circular street is short circular street in short ci	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3-3, EN BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-2, EN61	N61547	
&	Short Circuit Protection Withstand Voltage Insulation Resistance Safety Standards	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC CCC CC KC CUL UL CCC CC C	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short circular street is short circular street in short ci	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13, EN62384  KC61347-1, KC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, AS 61347-2-13  EN61347-1, AS 61347-2-13  EN61347-1, AS 61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3-3, EN BS EN IEC 55015, BS EN IEC 61000-3-2, EN IECS-005	N61547	
&	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission	Enter hi I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA UL UL UL CCC CUL UL UL UL CCC CUL UL U	ccup mode if short circular street is short circular street if short circular street is short circular street in short circular street is short circular street in short c	Lit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3-3, EN BS EN IEC 55015, BS EN IEC 61000-3-2, EN IEC 61000-3-2, EN IECS-005  FCC PART 15B	N61547	
&	Short Circuit Protection Withstand Voltage Insulation Resistance Safety Standards	Enter hi I/P-O/F I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM CMC EAC UKCA UL CCC CE KC EAC RCM UKCA ENEC UL UL CCC CE KC EAC RCM UKCA CUL UL CCC EAC RCM UKCA	ccup mode if short circular 2:3750Vac 2:3750Vac 2:100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India Canada America China European Union Korea Russia	Lit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN  IS 15885 [PART 2/SEC 13]  CSA C22.2 N0.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN  KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, ENG1000-3-2, ENG1000-3-	N61547	
&	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission	Enter hi I/P-O/F I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA UL CCC CE KC EAC RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM UKCA CUL UL EN610C Networl	ccup mode if short circular 2:3750Vac 2:3750Vac 2:100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India Canada America China European Union Korea Russia Australia	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN6	N61547	
& EMC	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA CUL UL CCC CE KC EAC RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM	ccup mode if short circular 2:3750Vac 2:3750Vac 2:100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India Canada America China European Union Korea Russia Australia European Union Canada America China European Union Corea Russia Australia Britain Canada Australia Britain Canada Australia Britain Canada Australia	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 N0.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN ISC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3	N61547 SEN 61000-3-3, BS EN 61547	
&	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission  EMC Immunity Power Consumption	Enter hi I/P-O/F I/P-O/F I/P-O/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA UL CCC CE KC EAC RCM UKCA CUL UL EN610C Networl	ccup mode if short circular 2:3750Vac 2:3750Vac 2:100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India Canada America China European Union Korea Russia Australia European Union Canada America China European Union Corea Russia Australia Britain Canada Australia Britain Canada Australia Britain Canada Australia	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 NO.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN6	N61547 SEN 61000-3-3, BS EN 61547	
& EMC	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA CUL UL CCC CE KC EAC RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM UKCA RCM	ccup mode if short circular 2:3750Vac 2:3750Vac 2:100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India Canada America China European Union Korea Russia Australia European Union Canada America China European Union Corea Russia Australia Britain Canada America 0-4-2,3,4,5,6,8,11, EN ced standby power consumption	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN IS 15885 [PART 2/SEC 13]  CSA C22.2 N0.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN ISC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3	N61547 SEN 61000-3-3, BS EN 61547	
& EMC	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission  EMC Immunity Power Consumption	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA CUL UL CCC I EAC RCM UKCA I UL CCC I EAC RCM UKCA I UL I EN610C Netword No-load IEEE 17:	ccup mode if short circular 2:3750Vac 2:3750Vac 2:100MΩ/500VDC/25°C China Germany CB Member States European Union Korea Russia Australia Europe Britain India Canada America China European Union Korea Russia Australia European Union Canada America China European Union Corea Russia Australia Britain Canada America 0-4-2,3,4,5,6,8,11, EN ced standby power consumption	it occurs, and recover automatically  2/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, EN61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN  IS 15885 [PART 2/SEC 13]  CSA C22.2 N0.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN  KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, E	N61547 SEN 61000-3-3, BS EN 61547	
& EMC	Short Circuit Protection Withstand Voltage Insulation Resistance  Safety Standards  EMC Emission  EMC Immunity Power Consumption  Flicker/Stroboscopic Effect	Enter hi I/P-0/F I/P-0/F I/P-0/F CCC TUV CB CE KC EAC RCM ENEC UKCA BIS CUL UL CCC CE KC EAC RCM UKCA UL CCC CE KC EAC RCM UKCA I UL CCC CE CE CO I CO I CO I CO I CO I CO I	ccup mode if short circular states and states are states and states are state	Lit occurs, and recover automatically  C/70%RH  GB19510.1, GB19510.14  EN61347-1, EN61347-2-13, EN62493  IEC61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  EN61347-1, IEC61347-2-13  IEC61347-1, IEC61347-2-13  AS 61347-1, IEC61347-2-13  EN61347-1, EN61347-2-13  EN61347-1, EN61347-2-13, EN62384  BS EN 61347-1, EN 61347-2-13, EN62384  BS EN 61347-1, BS EN 61347-2-13, BS EN  IS 15885 [PART 2/SEC 13]  CSA C22.2 N0.250.13  UL 8750  GB/T17743, GB17625.1  EN55015, EN61000-3-2, EN61000-3-3, EN  KSC 9815, KSC 9547  IEC62493, IEC61547, EH55015  EN55015, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-2, EN61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 55015, BS EN IEC 61000-3-3, EN  BS EN IEC 5005	N61547 SEN 61000-3-3, BS EN 61547	




# **Product Size**


Unit: mm







# Wiring Diagram







### **Current and Parameters Sheet**

Set output current on the NFC programmer or via the App					
	Output Current (I) Range	300-952mA	953-1050mA		
SE-40-300-1050-W1A	Output Voltage (U) Range	9-42Vdc	See the curve below for details		
	Output Power (P) Range	2.7-40W	8.577-40W		

Set output current on the NFC programmer or via the App					
	Output Current (I) Range	200-714mA	715-800mA		
SE-30-200-800-W1A	Output Voltage (U) Range	9-42Vdc	See the curve below for details		
	Output Power (P) Range	1.8-30W	6.435-30W		







Output Voltage - Output Current

SE-40-300-1050-W1A SE-30-200-800-W1A


# Protective Housing Application Diagram




# **Installation Precautions**



Please do not stack the products. The distance between two products should be  $\geqslant$ 15cm so as not to affect heat dissipation and the lifespan of the products.





Please not place the products on LED drivers. The distance between the product and the driver should be  $\geqslant$ 15cm so as not to affect heat dissipation and shorten the lifespan of the products.



## Work with a NFC programmer (LT-NFC)

Change the output current, power-on fading time and other parameters on the NFC programmer. After modification, batch parameters can be written to the driver.

\* Before you begin setting the parameters of the driver on the NFC programmer, please make sure the driver is powered off.



#### 1. Read the LED driver

Power the programmer by using the USB cable, then select "NFC Driver Settings" and press "OK" button. Next, keep the programmer's sensing area close to the NFC logo of the driver to read the driver parameters.

#### 2. Change the driver parameters (Output current/Power-on fading time)

On the home page of the programmer, press "Av" button to select the parameters you want to change and press the "OK" button to edit them. Then, press "Av" button to adjust the parameter values and press "de "OK" button.


Note: (1) If the current value you set is out of range, The programmer will report an error; (2) Power-on fading time range: 0-9s.

#### 3. Write to the driver

On the home page of the programmer, press the " A v" button to select [ >Ready to Write], then press the "OK" button. After the screen displays "Ready to write...", please keep the programmer's sensing area close to the NFC logo of the driver. When the screen displays "Write succeeded", it means the parameters have been successfully changed.











# Use the NFC Lighting APP

Scan the QR code below with your mobile phone and follow the prompts to complete the APP installation (According to performance requirements, you need to use a NFC-capable Android phone, or an iphone 8 and later that are compatible with iOS 13 or higher).



\* Before you begin setting the parameters of the driver on the NFC programmer or via the APP, please make sure the driver is powered off.

### Read/Write the LED driver

Use your NFC-capable phone to read the driver parameters, then set the output current, dimming mode, low power mode, other parameters. Save your settings and hold your phone close to the driver again, so the parameters can be easily written to the driver.

### 1. Read the LED driver

On the APP home page, click [Read/Write LED driver] , then keep the programmer's sensing area close to the NFC logo of the driver to read the driver parameters.

### 2. Edit the parameters

Click [Parameter settings] to edit the advanced parameters, like output current, dimming mode, ow power mode, adjustable voltage, etc.

### 3. Write to the drive

After completing the parameter settings, click [Write] in the upper right corner, and keep the programmer's sensing area close to the NFC logo of the driver, so the parameters can be written to the driver.











### Write/Read on the NFC programmer

Connect the NFC programmer to your phone and read the driver parameters with your phone. After editing the solution in the mobile App, you can sync it to the NFC programmer and write advanced parameters to mass LED drivers.

#### 1. Connect to the NFC programmer

Enable Bluetooth on your phone and power the NFC programmer first. Then press the button on the programmer to switch to "BLE Connection" and press "OK" button to wait for Bluetooth connection. On the APP home page, click [Write/Read on NFC programmer] — [Next] to search for the programmer and connect to it.

#### 2. Read the LED driver

On the "Programmer information" page, choose any solution for editing. Then keep the programmer's sensing area close to the NFC logo of the driver, to read the driver parameters.

#### 3. Edit the parameters

Click [Parameter settings] to edit the advanced parameters, like output current, dimming mode, ow power mode, adjustable voltage, etc. Then click [Save] in the top right.

#### 4 Write to the LFD driver

When the programmer screen shows "Sync ... succeeded", click "BACK" button to return to the home page and switch to the "APP Solutions", then press the "OK" button to access the optional solutions. Select the corresponding solution by pressing the " + " button, then keep the programmer's sensing area close to the NFC logo of the driver. After this, the advanced solution can be written to a large number of the same model drivers.




















For more advanced solution settings, please scan the QR code below and check out the NFC programmer manual (model: LT-NFC).







# Relationship Diagrams












SE-40-300-1050-W1A











Modulation Area Diagram



## Flicker Test Sheet



The output frequeny is 0Hz in 100% brightness and its corresponding modulation is 0%, which could not be shown in the right chart.



# **Packaging Specifications**

Model	SE-40-300-1050-W1A	SE-30-200-800-W1A
Carton Dimensions	320×275×106mm(L×W×H)	320×275×106mm(L×W×H)
Quantity	20 PCS/Layer; 2 Layers/Carton; 40 PCS/Carton	20 PCS/Layer; 2 Layers/Carton; 40 PCS/Carton
Weight	0.17 kg/PC; 7.6 kg±5%/Carton	0.15 kg/PC; 6.8 kg±5%/Carton

# Packaging Image



Inner Packaging Box



Carton Packaging



# Transportation and Storage

1. Transportation

Products can be shipped via vehicles, boats and planes.

During transportation, products should be protected from rain and sun. Please avoid severe shock and vibration during the loading and unloading process.

2. Storage

The storage conditions should comply with the Class I Environmental Standards. The products that have been stored for more than six months are recommended to be re-inspected and can be used only after they have been qualified.

### **Attentions**

- This product must be installed and adjusted by a qualified professional.
- This product is non-waterproof (special models excepted). Please avoid the sun and rain. When installed outdoors, please ensure it is mounted in a water proof enclosure.
- $\bullet \quad \mathsf{Good} \ \mathsf{heat} \ \mathsf{dissipation} \ \mathsf{will} \ \mathsf{extend} \ \mathsf{the} \ \mathsf{life} \ \mathsf{the} \ \mathsf{product}. \ \mathsf{Please} \ \mathsf{install} \ \mathsf{the} \ \mathsf{product} \ \mathsf{in} \ \mathsf{a} \ \mathsf{environment} \ \mathsf{with} \ \mathsf{good} \ \mathsf{ventilation}.$
- When you install this product, please avoid being near a large area of metal objects or stacking them to prevent signal interference.
- · Please keep the product away from a intense magnetic field, a high pressure area or a place where lightning is easy to occur.
- $\bullet \quad \text{Please check whether the working voltage used complies with the parameter requirements of the product.}\\$
- Before you power on the product, please make sure all the wiring is correct in case of incorrect connection that may cause a short circuit and damage the components, or trigger a accident
- If a fault occurs, please do not attempt to fix the product by yourself. If you have any question, please contact the supplier.
- \* This manual is subject to changes without further notice. Product functions depend on the goods. Please feel free to contact our official distributors if you have any question.

# Warranty Agreement

- Warranty periods from the date of delivery: 5 years.
- $\bullet \quad \text{Free repair or replacement services for quality problems are provided within warranty periods}.$

Warranty exclusions below:

- Beyond warranty periods.
- Any artificial damage caused by high voltage, overload, or improper operations.
- Products with severe physical damage.
- Damage caused by natural disasters and force majeure.
- Warranty labels and barcodes have been damaged.
- No any contract signed by LTECH.
- 1. Repair or replacement provided is the only remedy for customers. LTECH is not liable for any incidental or consequential damage unless it is within the law.
- 2. LTECH has the right to amend or adjust the terms of this warranty, and release in written form shall prevail.



# **Update Log**

Version	Updated Time	Update Content	Updated by
Α0	2023.02.23	Original version	Liu Weili