

Installation Instructions – PM169

**SL201/SL211/SLDL624F/SLDL644T
Mini-LIGHT'Z (1W)**

Classification: IC-F / IC-4

Recessed luminaire where approved fixed building insulation material that can be safely be continuously exposed to 90°C is allowed to abut and cover the luminaire.

350mA / 700mA constant current driver is non-coverable

Constant current:

350mA or 700mA (see luminaire cable label)

Approved insulation:

Pink Batts, Bradford Gold, InsulPro Polyester insulation, Ecofleece, Autex Greenstuf, Earthwool, Premier insulation.

Contact Switch Lighting for other insulation information.

Caution:

Always turn power off when connecting or disconnecting luminaires.

Warranty:

Luminaire: 7 years (5 years if outdoors)

Proof of purchase is required. See website for full warranty conditions.

How many constant current lights per driver?

Scan the QR code to check max & min number of luminaires in the Driver Tables and Dimmer information in Tips & Tricks.

Or visit www.switch-lighting.co.nz and navigate to Library / Tips and Tricks




Required clearance: Standard

Required clearance from structural members and building elements:

SCB = 0mm HCB = 0mm

Cut-out



SL201 16mm

SL211 20mm

SLDL624F 32mm

SLDL644T 32mm

Installation:

(by registered electrician only)

1. Ensure driver is disconnected from mains supply before connecting LED/s.
2. Connect the LED/s and driver in **SERIES**.
3. Ensure connections are watertight – LED/s and driver may be permanently damaged if not wired correctly.

