



LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 44.25 lm/W
MODEL		I <sub>max</sub> (cd)	882.5	S/MH (C0/180)		0.47
NOMINAL POWER (W)		LOR (%)	100.0	S/MH (C90/270)		0.60
RATED VOLTAGE (V)		TOTAL FLUX (lm)	340.71	η UP,DN (C0-180)		0.0,48.7
NOMINAL FLUX (lm)	340.709	CIE CLASS	DIRECT	η UP,DN (C180-360)		0.0,51.3
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM		0.50
TEST VOLTAGE (V)		η down (%)	100.0	CIBSE SHR MAX		0.55



C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: Jason  
Test Date: 03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System: EVERFINE GO-i300\_v1 SYSTEM V2.0.401  
Humidity: 65.0%  
Test Distance: 3.160m [K=1.0000]  
Remarks:

### ZONAL FLUX DIAGRAM

#### ZONAL FLUX DIAGRAM:


$\gamma$	C0	C45	C90	C135	C180	C225	C270	C315	$\gamma$	$\Phi$ zone	$\Phi$ total	%lum,lamp
10	760.5	704.3	632.0	573.0	575.1	617.8	717.0	751.8	0- 10	71.74	71.74	21.1,21.1
20	412.7	359.4	290.7	262.5	268.7	309.0	375.0	407.6	10- 20	136.7	208.4	61.2,61.2
30	134.6	126.2	104.8	90.00	91.49	112.3	144.0	144.4	20- 30	95.97	304.4	89.3,89.3
40	18.00	7.706	5.408	5.895	6.594	6.405	9.962	17.42	30- 40	31.95	336.3	98.7,98.7
50	2.074	1.625	1.649	1.588	1.948	1.483	2.013	2.162	40- 50	2.861	339.2	99.6,99.6
60	0.6677	0.5376	0.5437	0.4506	0.5432	0.4588	0.6613	0.6697	50- 60	0.9464	340.1	99.8,99.8
70	0.2532	0.2109	0.2137	0.1838	0.1908	0.1766	0.2270	0.2361	60- 70	0.3299	340.5	99.9,99.9
80	0.1483	0.1343	0.1263	0.1071	0.0982	0.1187	0.1389	0.1428	70- 80	0.1720	340.6	100,100
90	0	0	0	0	0	0	0	0	80- 90	0.0658	340.7	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_v1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	791	512
80	682	578
75	586	513
70	591	496
65	723	594
60	1067	864
55	1712	1330
50	2577	2038
45	4058	3167


C Range: 0 - 360DEG  
 C Interval: 30.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: Jason  
 Test Date: 03 August 2020

γ Range: 0 - 90DEG  
 γ Interval: 1.0DEG  
 Test System: EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
 Humidity: 65.0%  
 Test Distance: 3.160m [K=1.0000]  
 Remarks:

## CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

### WEC AND CCEC

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm																	
NAME: SLDL216T-30SDP-TWD15									TYPE:						WEIGHT:		
SPEC.:									DIM.:						SERIAL No.:		
MFR.: Switch Lighting									SUR.:						Shielding Angle:		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.153	.087	.028	.147	.084	.027	.134	.077	.025	.123	.071	.023	.112	.065	.021	
2.0	.144	.079	.024	.139	.076	.024	.128	.071	.022	.119	.067	.021	.110	.062	.020	
3.0	.136	.072	.022	.131	.070	.021	.123	.066	.020	.115	.063	.019	.107	.059	.018	
4.0	.129	.067	.020	.125	.065	.019	.117	.062	.019	.110	.059	.018	.104	.056	.017	
5.0	.122	.062	.018	.119	.061	.018	.112	.059	.017	.106	.056	.017	.101	.054	.016	
6.0	.116	.058	.017	.113	.057	.016	.108	.055	.016	.103	.053	.016	.098	.051	.015	
7.0	.111	.055	.016	.109	.054	.015	.104	.052	.015	.099	.051	.015	.095	.049	.014	
8.0	.106	.052	.015	.104	.051	.014	.100	.050	.014	.096	.049	.014	.092	.047	.014	
9.0	.102	.049	.014	.100	.049	.014	.096	.048	.013	.093	.046	.013	.089	.045	.013	
10.0	.098	.047	.013	.096	.047	.013	.093	.046	.013	.090	.044	.013	.087	.044	.012	

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.169	.158	.147	.145	.135	.126	.099	.093	.087	.057	.054	.051	.018	.017	.016		
2.0	.153	.133	.116	.131	.114	.100	.090	.079	.070	.052	.046	.041	.017	.015	.013		
3.0	.139	.113	.093	.119	.098	.081	.082	.068	.057	.047	.040	.033	.015	.013	.011		
4.0	.127	.098	.076	.109	.085	.066	.075	.059	.047	.043	.035	.028	.014	.011	.009		
5.0	.117	.086	.063	.101	.075	.055	.070	.052	.039	.040	.031	.023	.013	.010	.008		
6.0	.109	.077	.053	.094	.066	.046	.065	.046	.033	.038	.027	.019	.012	.009	.006		
7.0	.102	.069	.045	.088	.060	.039	.061	.042	.028	.035	.025	.017	.011	.008	.005		
8.0	.096	.062	.039	.083	.054	.034	.057	.038	.024	.033	.022	.014	.011	.007	.005		
9.0	.091	.057	.034	.078	.049	.029	.054	.035	.021	.032	.020	.012	.010	.007	.004		
10.0	.086	.052	.030	.074	.045	.026	.052	.032	.018	.030	.019	.011	.010	.006	.004		

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

### UGR(Unified Glare Rating) Table

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm											
NAME: SLDL216T-30SDP-TWD15					TYPE:			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.: Switch Lighting					SUR.:			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H		19.2	20.0	19.4	20.2	20.3	17.5	18.3	17.7	18.4	18.6
	3H	19.1	19.8	19.3	20.0	20.2	17.3	18.1	17.6	18.2	18.4
	4H	19.0	19.7	19.3	19.9	20.1	17.3	17.9	17.5	18.2	18.4
	6H	18.9	19.5	19.2	19.8	20.0	17.2	17.8	17.5	18.1	18.3
	8H	18.9	19.5	19.2	19.7	20.0	17.1	17.8	17.4	18.0	18.3
	12H	18.8	19.4	19.1	19.7	19.9	17.1	17.7	17.4	18.0	18.2
4H	2H	19.0	19.7	19.2	19.9	20.1	17.3	17.9	17.5	18.1	18.4
	3H	18.8	19.4	19.1	19.7	19.9	17.1	17.7	17.4	17.9	18.2
	4H	18.7	19.3	19.1	19.6	19.9	17.0	17.5	17.3	17.8	18.1
	6H	18.6	19.1	19.0	19.4	19.8	16.9	17.4	17.3	17.7	18.1
	8H	18.6	19.0	19.0	19.4	19.7	16.9	17.3	17.3	17.7	18.0
	12H	18.5	18.9	18.9	19.3	19.7	16.8	17.2	17.2	17.6	18.0
8H	4H	18.6	19.0	19.0	19.4	19.7	16.9	17.3	17.2	17.6	18.0
	6H	18.5	18.8	18.9	19.2	19.6	16.8	17.1	17.2	17.5	17.9
	8H	18.4	18.7	18.9	19.2	19.6	16.7	17.0	17.2	17.5	17.9
	12H	18.4	18.6	18.8	19.1	19.6	16.7	16.9	17.1	17.4	17.9
12H	4H	18.5	18.9	18.9	19.3	19.7	16.8	17.2	17.2	17.6	18.0
	6H	18.4	18.7	18.9	19.2	19.6	16.7	17.0	17.2	17.5	17.9
	8H	18.4	18.6	18.8	19.1	19.6	16.7	16.9	17.1	17.4	17.9
Variations with the observer position at spacings:											
S = 1.0H	+ 6.0 / -12.0					+ 3.1 / - 6.3					
1.5H	+ 8.7 / -11.5					+ 5.3 / - 4.9					
2.0H	+ 4.4 / - 3.3					+ 3.1 / - 2.3					

CIE Pub.117, 340.7 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -3.7)

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

### UTILIZATION FACTORS TABLE

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	91	85	82	90	85	82	90	85	81	78
0.80	98	93	89	97	92	89	96	92	89	85
1.00	102	97	93	101	96	93	99	96	92	89
1.25	105	100	97	104	100	97	102	99	96	92
1.50	108	103	100	106	103	100	104	101	99	95
2.00	110	106	103	108	105	102	106	103	101	96
2.50	111	108	105	110	107	104	107	104	102	97
3.00	113	110	107	111	108	106	108	105	104	98
4.00	114	112	110	112	110	109	109	107	106	99
5.00	116	114	112	114	112	110	110	108	107	100
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

**ISOCANDELA DIAGRAM**

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:




C Range: 0 - 360DEG  
 C Interval: 30.0DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators: Jason  
 Test Date: 03 August 2020

γ Range: 0 - 90DEG  
 γ Interval: 1.0DEG  
 Test System: EVERFINE GO-i300\_v1 SYSTEM V2.0.401  
 Humidity: 65.0%  
 Test Distance: 3.160m [K=1.0000]  
 Remarks:



AAI Figure

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

ISOLUX DIAGRAM

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

### LED Avg.L Report

Test:U:230.00V I:0.0350A P:7.7000W PF:0.9660 Freq:50.00Hz Lamp Flux:340.709x1 lm		
NAME: SLDL216T-30SDP-TWD15	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	647
L_0~180 (75) av	504
L_0~180 (85) av	564
L_90~270 (65) av	636
L_90~270 (75) av	519
L_90~270 (85) av	663
L_45 (65) av	551
L_45 (75) av	483
L_45 (85) av	596

Standard: GB/T 29293-2012

C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:Jason  
Test Date:03 August 2020

γ Range: 0 - 90DEG  
γ Interval: 1.0DEG  
Test System:EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity:65.0%  
Test Distance:3.160m [K=1.0000]  
Remarks:

## Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 30.0DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators: Jason  
Test Date: 03 August 2020

$\gamma$  Range: 0 - 90DEG  
 $\gamma$  Interval: 1.0DEG  
Test System: EVERFINE GO-i300\_V1 SYSTEM V2.0.401  
Humidity: 65.0%  
Test Distance: 3.160m [K=1.0000]  
Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity: 65.0%
Test Distance: 3.160m [K=1.0000]
Remarks:

```