

Installation Instructions – PM166

SLDL614T Feature-LIGHTZ

Classification: IC-F / IC-4

Recessed luminaire where approved fixed building insulation material that can be safely be continuously exposed to 90°C is allowed to abut and cover the luminaire.

700mA (max) constant current driver is non-coverable

Constant current:

700mA (max)

Approved insulation:

Pink Batts, Bradford Gold, InsulPro Polyester insulation, Ecofleece, Autex Greenstuf, Earthwool, Premier insulation.

Contact Switch Lighting for other insulation information.

Caution:

Always turn power off when connecting or disconnecting luminaires.

Note:

IP44 rated.

Suitable for indoor use or outdoor use in dry protected location.

Warranty:

Luminaire: 7 years

Driver: 5 years

Proof of purchase is required. See website for full warranty conditions.

How many constant current lights per driver?

Click on the QR code to check max & min number of lights to connect and dimmer information or visit www.switch-lighting.co.nz/ Library / Tips and Tricks




Required clearance: Standard

Required clearance from structural members and building elements:

SCB = 0mm **HCB** = 0mm

Cut-out



Installation:

(by registered electrician only)

1. Ensure driver is disconnected from mains supply before connecting LED/s.
2. Connect the LED/s and driver in **SERIES**.
3. Ensure connections are watertight – LED/s and driver may be permanently damaged if not wired correctly.

