



LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 67.96 lm/W
MODEL		I _{max} (cd)	244.3	S/MH (C0/180)	1.24	
NOMINAL POWER (W)		LOR (%)	100.0	S/MH (C90/270)	1.24	
RATED VOLTAGE (V)		TOTAL FLUX (lm)	659.21	η UP,DN (C0-180)	0.0,49.6	
NOMINAL FLUX (lm)	659.21	CIE CLASS	DIRECT	η UP,DN (C180-360)	0.0,50.4	
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	1.25	
TEST VOLTAGE (V)		η down (%)	100.0	CIBSE SHR MAX	1.35	



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_v1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum,lamp
10	239.4	239.4	239.1	239.3	239.6	240.0	240.1	240.0	0- 10	23.09	23.09	3.5,3.5
20	225.7	225.2	224.9	225.2	225.2	226.3	226.6	226.0	10- 20	65.94	89.03	13.5,13.5
30	202.8	202.5	202.3	202.5	203.2	204.0	204.4	203.6	20- 30	99.21	188.2	28.6,28.6
40	173.3	172.8	172.4	172.7	173.4	174.5	174.9	173.8	30- 40	118.3	306.5	46.5,46.5
50	138.0	137.5	136.6	137.3	138.0	139.3	139.5	138.5	40- 50	120.6	427.1	64.8,64.8
60	98.88	98.19	97.13	97.80	98.72	100.2	101.3	99.88	50- 60	106.2	533.3	80.9,80.9
70	58.20	57.22	56.06	57.05	57.83	59.52	60.55	59.07	60- 70	77.84	611.2	92.7,92.7
80	19.69	18.71	17.76	18.72	19.16	20.33	21.34	20.22	70- 80	40.43	651.6	98.8,98.8
90	0.0174	0.0102	0.0080	0.0094	0.0385	0.0780	0.1218	0.0740	80- 90	7.620	659.2	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_v1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	20855	17361
80	37554	33892
75	48951	46333
70	56354	54309
65	61531	60090
60	65499	64366
55	68666	67746
50	71103	70417
45	73165	72689


C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)									
0.0																
1.0	.296	.168	.053	.289	.165	.052	.276	.158	.050	.263	.152	.049	.252	.146	.047	
2.0	.282	.155	.047	.276	.152	.047	.264	.147	.046	.254	.142	.045	.244	.138	.043	
3.0	.263	.140	.042	.258	.138	.042	.247	.134	.041	.238	.130	.040	.229	.127	.039	
4.0	.244	.127	.037	.239	.125	.037	.230	.122	.036	.221	.119	.036	.214	.116	.035	
5.0	.226	.115	.033	.222	.114	.033	.214	.111	.033	.206	.109	.032	.199	.106	.032	
6.0	.210	.105	.030	.207	.104	.030	.199	.102	.030	.193	.100	.029	.186	.098	.029	
7.0	.196	.097	.027	.193	.096	.027	.186	.094	.027	.180	.092	.027	.175	.091	.027	
8.0	.183	.090	.025	.180	.089	.025	.175	.087	.025	.169	.086	.025	.164	.084	.025	
9.0	.172	.083	.023	.169	.083	.023	.164	.081	.023	.159	.080	.023	.155	.079	.023	
10.0	.162	.078	.022	.160	.077	.021	.155	.076	.021	.151	.075	.021	.146	.074	.021	

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.179	.156	.135	.153	.134	.117	.105	.092	.081	.060	.053	.047	.019	.017	.015		
2.0	.171	.132	.099	.146	.114	.086	.100	.079	.060	.058	.046	.035	.019	.015	.011		
3.0	.163	.114	.075	.140	.099	.065	.096	.068	.046	.055	.040	.027	.018	.013	.009		
4.0	.156	.101	.059	.133	.087	.051	.092	.061	.036	.053	.036	.021	.017	.012	.007		
5.0	.148	.090	.048	.127	.078	.042	.088	.055	.029	.051	.032	.017	.016	.010	.006		
6.0	.141	.082	.040	.121	.071	.035	.084	.050	.024	.049	.029	.015	.016	.010	.005		
7.0	.134	.075	.034	.116	.065	.029	.080	.046	.021	.046	.027	.012	.015	.009	.004		
8.0	.128	.069	.029	.110	.060	.025	.076	.042	.018	.044	.025	.011	.014	.008	.004		
9.0	.122	.064	.025	.105	.056	.022	.073	.039	.016	.042	.023	.009	.014	.008	.003		
10.0	.116	.060	.023	.100	.052	.020	.070	.037	.014	.041	.022	.008	.013	.007	.003		

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm											
NAME: SLED715F-W1S1-P-TW-2700K					TYPE:			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.: Switch Lighting					SUR.:			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H	y = 2H	28.9	30.4	29.2	30.6	30.8	28.9	30.4	29.2	30.6	30.8
	3H	30.3	31.7	30.6	31.9	32.1	30.3	31.6	30.6	31.9	32.1
	4H	30.8	32.1	31.1	32.3	32.6	30.7	32.0	31.0	32.3	32.5
	6H	31.0	32.3	31.4	32.6	32.8	31.0	32.2	31.3	32.5	32.7
	8H	31.1	32.3	31.4	32.6	32.9	31.0	32.2	31.3	32.5	32.7
	12H	31.1	32.2	31.4	32.5	32.8	31.0	32.1	31.3	32.4	32.7
4H	2H	29.5	30.8	29.8	31.1	31.3	29.5	30.8	29.8	31.1	31.3
	3H	31.0	32.2	31.4	32.5	32.8	31.0	32.2	31.4	32.4	32.7
	4H	31.6	32.6	32.0	33.0	33.3	31.6	32.6	31.9	32.9	33.3
	6H	32.0	32.9	32.4	33.2	33.6	31.9	32.8	32.3	33.2	33.5
	8H	32.0	32.9	32.4	33.3	33.6	32.0	32.8	32.4	33.2	33.6
	12H	32.0	32.8	32.5	33.2	33.6	32.0	32.8	32.4	33.1	33.5
8H	4H	31.8	32.7	32.2	33.0	33.4	31.8	32.6	32.2	33.0	33.4
	6H	32.2	33.0	32.7	33.4	33.8	32.2	32.9	32.6	33.3	33.7
	8H	32.4	33.0	32.8	33.4	33.9	32.3	32.9	32.8	33.4	33.8
	12H	32.4	32.9	32.9	33.4	33.9	32.3	32.9	32.8	33.3	33.8
12H	4H	31.8	32.6	32.2	33.0	33.4	31.8	32.5	32.2	32.9	33.3
	6H	32.3	32.9	32.7	33.3	33.8	32.2	32.8	32.7	33.3	33.7
	8H	32.4	32.9	32.9	33.4	33.9	32.3	32.9	32.8	33.3	33.8
Variations with the observer position at spacings:											
S = 1.0H		+ 0.2 / - 0.2					+ 0.2 / - 0.2				
1.5H		+ 0.2 / - 0.3					+ 0.2 / - 0.4				
2.0H		+ 0.3 / - 0.3					+ 0.3 / - 0.3				

CIE Pub.117, 659.2 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -1.4)

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	59	47	40	58	47	40	57	46	40	34
0.80	69	57	50	68	57	50	66	56	49	43
1.00	77	66	59	76	66	59	74	67	58	51
1.25	84	74	67	83	73	67	80	72	66	59
1.50	89	80	73	87	79	72	85	77	71	64
2.00	96	88	81	94	86	81	91	84	79	71
2.50	100	92	86	98	91	85	94	88	84	75
3.00	103	96	91	101	95	90	97	92	88	80
4.00	107	101	97	105	100	96	100	96	93	84
5.00	109	105	101	107	103	99	102	99	96	87
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_v1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

AAI Figure

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 30.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:Jason
 Test Date:09 June 2020

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
 Humidity:65.0%
 Test Distance:3.160m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
 C Interval: 30.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:Jason
 Test Date:09 June 2020

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
 Humidity:65.0%
 Test Distance:3.160m [K=1.0000]
 Remarks:

LED Avg.L Report

Test:U:230.00V I:0.0440A P:9.7000W PF:0.9690 Freq:50.00Hz Lamp Flux:659.21x1 lm		
NAME: SLED715F-W1S1-P-TW-2700K	TYPE:	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: Switch Lighting	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	61501
L_0~180 (75) av	48755
L_0~180 (85) av	20284
L_90~270 (65) av	61824
L_90~270 (75) av	48865
L_90~270 (85) av	20861
L_45 (65) av	61732
L_45 (75) av	48859
L_45 (85) av	20529

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:Jason
Test Date:09 June 2020

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 30.0DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: Jason
 Test Date: 09 June 2020

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-i300_V1 SYSTEM V2.0.401
 Humidity: 65.0%
 Test Distance: 3.160m [K=1.0000]
 Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-i300_V1 SYSTEM V2.0.401
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks:

```